



बरेङ गाउँपालिका
गाउँ कार्यपालिकाको कार्यालय

हुग्लेशिर्, बागलुङ
गण्डकी प्रदेश, नेपाल
२०७३



पत्र संख्या : २०८२/०८३
सूचना नं. : ६८

मिति : २०८३/०१/०८
नेपाल संवत् : १९४६ बछलाघ्न

दररेट उपलब्ध गराउने सम्बन्धी सूचना ।

प्रस्तुत सन्दर्भमा यस गाउँपालिकाको आर्थिक वर्ष २०८२/०८३ मा सङ्घीय सरकारबाट हस्तान्तरित वार्षिक स्वीकृत विशेष अनुदानको बर्थिङ सेन्टर तथा स्वास्थ्य संस्था व्यवस्थापन एवम् सुदृढीकरण कार्यक्रम अनुसार गाउँपालिकामा रहेका स्वास्थ्य संस्थाहरूको लागि विद्युतीय सामग्रीहरू खरिद गर्नु पर्ने भएको हुदाँ विद्युतीय सामग्रीहरू उपलब्ध गराउन इच्छुक आपुर्तिकर्ताले यो सूचना प्रकाशन भएको मितिले ०७ (सात) दिन भित्र दररेट उपलब्ध गराउनुहुन यो सूचना प्रकाशन गरिएको छ ।



२०८३/०१/०८
(बद्री नाथ पोखरेल)

प्रमुख प्रशासकीय अधिकृत
बद्री नाथ पोखरेल
गाउँपालिका प्रशासकीय अधिकृत

नोट:- विद्युतीय सामग्रीहरूको विवरण र Technical Specification यसै पत्र साथ संलग्न गरिएको छ ।


Technical Specifications for Electric Heater

| S.N | Feature | Specifications | Bidder's Offer |
|-----|------------------|--|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Type | Quartz Heater | |
| 4 | Heating Elements | Minimum 2 or 3 Quartz Heating Tubes | |
| 5 | Power Settings | Adjustable heat settings (e.g., 400W / 800W / 1200W) with independent switches for each tube | |
| 6 | Safety Features | Mandatory Safety Tip-over Switch (Automatic shut-off if tilted or fallen) | |
| 7 | Protection | Protective safety mesh grill covering all heating elements | |
| 8 | Oscillation | Wide-angle oscillation (Swing) function | |
| 9 | Body/Build | High-impact heat resistant plastic/metal body with carry handle | |
| 10 | Warranty | Minimum 1 year on product/heating elements | |


Prepared By:

Name: Er.Abhishek Pradhan


Designation: Sr.BMET

NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu


Technical Specifications for Silent Diesel Generator (10 kVA)

| S.N | Feature | Specifications | Bidder's Offer |
|-----|-----------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Type | Silent Canopy Type, Self-Regulated (AVR Equipped) | |
| 4 | Rated Power | Minimum 10 kVA | |
| 5 | Voltage/Freq | 230V-240V, Single Phase, 50Hz | |
| 6 | Engine | Vertical, Inline, Liquid/Air Cooled, 1500 RPM | |
| 7 | Fuel System | Diesel; Fuel Tank Capacity minimum 30 Liters | |
| 8 | Noise Level | ≤70 dB at 7 meters distance | |
| 9 | Protection | IP23 Rating (Weatherproof for outdoor use) | |
| 10 | Starting System | Electric Start (Battery included) with Manual Recoil backup | |
| 11 | Safety | Low Oil Pressure and High Water Temp. Auto-shutdown | |
| 12 | Warranty | Minimum 1 year or 1000 running hours | |


Prepared By:

Name: Er.Abhishek Pradhan


Designation: Sr.BMET

NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu


Technical Specifications for Inverter with Battery Backup System

| S.N | Feature | Specifications | Bidder's Offer |
|----------------------|------------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| Inverter Unit | | | |
| 3 | Capacity | Minimum 1100VA / 12V System (to support the 160Ah battery) | |
| 4 | Waveform | Pure Sine Wave (Mandatory for sensitive medical/electronic equipment) | |
| 5 | Input Voltage | 12V DC (Nominal) | |
| 6 | Output Voltage | 220V-230V AC, 50Hz | |
| 7 | Efficiency | Minimum 90% or higher | |
| 8 | Charging Current | Adjustable charging current (supporting 10A to 20A range) | |
| 9 | Display | LCD/LED Display for monitoring: Battery Level, Load %, and Faults | |
| 10 | Protection | Short Circuit, Overload, Battery Low and Reverse Polarity protection | |
| 11 | Temp. Range | Operating Temperature: 10°C to 55°C | |
| Battery Unit | | | |
| 12 | Type | Deep Cycle Tubular Lead Acid Battery (Low Maintenance) | |
| 13 | Capacity | Minimum 160Ah at C20 rating | |
| 14 | Voltage | 12V DC | |
| 15 | Build | Low water loss design with level float indicators | |
| 16 | Weight | Minimum 50 kg (including electrolyte) | |
| 17 | Accessories | Complete set of battery inter-connectors and heavy-duty DC cables | |
| 18 | Warranty | Inverter: Min. 2 Years; Battery: Min. 36 Months Replacement | |


Prepared By:

Name: Er.Abhishek Pradhan

Designation: Sr.BMET

NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu



Technical Specifications for Electric and Gas Heater

| S.N | Feature | Specifications | Bidder's Offer |
|-----|-------------------------|--|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Type | Hybrid Heater (Dual Gas and Electric Function) | |
| 4 | Fuel Source | LPG (Liquid Petroleum Gas) | |
| 5 | Gas Consumption | Approx. 300 g/h or less (at maximum setting) | |
| 6 | Electric Heat Level | Minimum 3 settings (e.g., 400W / 800W / 1200W) | |
| 7 | Heating Element | Quartz or Halogen tubes for electric mode; Ceramic plates for gas mode | |
| 8 | Oxygen Sensor Mandatory | ODS (Oxygen Depletion Sensor) for automatic shut-off | |
| 9 | Safety Features | Safety Tip-over Switch and Flame Failure Protection | |
| 10 | Ignition | Piezoelectric ignition (No match/lighter required) | |
| 11 | Portability | Heavy-duty Castor wheels for easy 360-degree movement | |
| 12 | Build | Heat-resistant powder-coated body with back cylinder cover/bracket | |
| 13 | Warranty | Minimum 1 year on both parts and services | |

Prepared By:

Name: Er.Abhishek Pradhan


Designation: Sr.BMET

NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu


Technical Specifications for Water Dispenser

| S.N | Feature | Specifications | Bidder's Offer |
|-----|---------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Type | Floor Standing with Top Loading bottle design | |
| 4 | Function | Hot and Normal (Room Temperature) water only | |
| 5 | Storage Tank | Hot: Min. 1.0 Liter; Normal: Capacity to be mentioned | |
| 6 | Tank Material | Food-grade Stainless Steel (SS304) for Hot tank | |
| 7 | Heating Power | Approximately 500W | |
| 8 | Indicators | LED Indicators for Power and Heating status | |
| 9 | Body Design | Durable high-impact plastic/metal body with removable drip tray | |
| 10 | Cabinet | Bottom storage cabinet (non-refrigerated/normal storage) | |
| 11 | Voltage | 220-240V, 50Hz | |


Prepared By:

Name: Er.Abbishek Pradhan
Designation: Sr.BMET
NEC Registration No.:5194"Elex & Comm"
Office: Civil Service Hospital,Kathmandu


Technical Specifications for Laptop

| S.N | Feature | Specifications | Bidder's Offer |
|-----|------------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Display | 14" to 15.6". Wide Screen, Minimum Resolution (1920×1080) | |
| 4 | Processors | Intel Core i5, 13th Generation or equivalent (at least 10-core, 12MB Cache, up to 4.60 GHz) | |
| 5 | Memory | At least 16GB DDR4/DDR5 RAM, Expandable up to 32 GB or higher | |
| 6 | Graphics | Integrated Graphics (Intel Iris Xe or equivalent) | |
| 7 | Storage | 512 GB Nvme SSD | |
| 8 | Battery | At least 3-cell Li-ion Battery (42Whr or higher) with Fast Charge support | |
| 9 | Operating System | Genuine Windows 11 Pro 64-bit | |
| 10 | I/O Ports | At least 2x USB 3.2, 1x USB-C (Power Delivery/DisplayPort), 1x HDMI 1.4/2.0, 1x Audio Jack | |
| 11 | Connectivity | Wi-Fi 6 (802.11ax) and Bluetooth 5.2 or higher | |
| 12 | Security | Trusted Platform Module (TPM) 2.0 | |
| 13 | Warranty | 1-year comprehensive warranty on parts and services | |



Prepared By:

Name: Er.Abhishek Pradhan


Designation: Sr.BMET

NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu

Technical Specifications for All-in-One Printer

| S.N | Feature | Specifications | Bidder's Offer |
|-----|------------------|--|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Function | Print, Scan, and Copy (All-in-One) | |
| 4 | Type | Laser | |
| 5 | Print Speed | Min. 8.5 ipm (Black) / 5.0 ipm (Color) or higher | |
| 6 | Print Resolution | Minimum 1200×1200 dpi | |
| 7 | Copy Speed | Up to 25 ppm (A4) or higher | |
| 8 | Scan resolution | 600×600 dpi or higher | |
| 9 | Interface | High-speed USB 2.0 and Wireless (Wi-Fi 802.11 b/g/n) | |
| 10 | Connectivity | Mobile Printing support | |
| 11 | Power Support | 220–240V, 50/60Hz | |
| 12 | Warranty | Minimum 1 year on both parts and services | |


Prepared By:

Name: Er.Abhishek Pradhan
Designation: Sr.BMET
NEC Registration No.:5194"Elect & Comm"
Office: Civil Service Hospital,Kathmandu



Technical Specifications for Desktop

| S.N | Feature | Specifications | Bidder's Offer |
|-----|------------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Processor | Intel Core i5 (12th Generation) or equivalent (Min. 6 Cores) | |
| 4 | RAM | 8GB DDR4 RAM (Must have at least one additional free slot) | |
| 5 | Storage | 512 GB M.2 NVMe SSD | |
| 6 | Monitor | 24-inch Full HD (1920×1080) LED Monitor | |
| 7 | Graphics | Integrated High Definition Graphics | |
| 8 | Networking | Integrated Ethernet (RJ-45) and Wi-Fi 5 or higher | |
| 9 | Connectivity: | Front:2x USB 3.2, Audio/Mic Jack; Rear: HDMI/DisplayPort, USB ports | |
| 10 | Audio | Integrated High Definition Audio with Internal Speaker | |
| 11 | Operating System | Windows 11 (64-bit) | |
| 12 | Input Devices | Standard USB Wired Optical Mouse and Keyboard | |
| 13 | Power Supply | 220–240V, 50Hz | |
| 14 | Warranty | Minimum 1 year on all parts and services | |

Prepared By:

Name: Er.Abhishek Pradhan

Designation: Sr.BMET


NEC Registration No.:5194"Elex & Comm"

Office: Civil Service Hospital,Kathmandu



Technical Specifications for Washing Machine

| S.N | Feature | Specifications | Bidder's Offer |
|-----|---------------------|---|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Function | Fully Automatic with Wash, Rinse and Spin cycles | |
| 4 | Capacity | Minimum 8 kg | |
| 5 | Loading Type | Front Loading | |
| 6 | Drum Material | High-grade Stainless Steel (Corrosion Resistant) | |
| 7 | Spin Speed | Minimum 1000 RPM or higher (for efficient water extraction) | |
| 8 | Display/Timer | Digital Display with Cycle Status and Time Remaining indicator | |
| 9 | Temperature Control | Built-in Heater with adjustable temperature settings (up to 60°C or higher for sterilization) | |
| 10 | Programs | Multiple wash programs | |
| 11 | Power Supply | 220-240V, 50Hz | |
| 12 | Certification | Manufacturer should be ISO 9001 Certified or equivalent | |
| 13 | Warranty | Minimum 2 years on the product and 5+ years on the Motor | |


Prepared By:

Name: Er.Abbishek Pradhan
Designation: Sr.BMET
NEC Registration No.:5194"Elex & Comm"
Office: Civil Service Hospital,Kathmandu



Technical Specifications for Split Air Conditioner (1.5 Ton)

| S.N | Feature | Specifications | Bidder's Offer |
|-----|-------------|--|----------------|
| 1 | Brand | To be Mentioned By Bidder | |
| 2 | Model | To be Mentioned By Bidder | |
| 3 | Type | Split Wall Mounted, Inverter Type | |
| 4 | Capacity | 1.5 Ton (18000 BTU/hr or higher) | |
| 5 | Compressor | Energy Efficient Rotary Inverter Compressor | |
| 6 | Condenser | 100% Copper Tubes | |
| 7 | Filtration | Multi-stage filtration (Anti-bacterial/Dust filter) | |
| 8 | Features | Turbo Cooling Mode, LCD Remote Control, Auto-Restart | |
| 9 | Noise Level | Indoor unit: ≤50 dB | |
| 10 | Accessories | ODU Bracket, 10ft Copper Pipe Set, and 10ft Drain Pipe | |
| 11 | Power | 220-240V, 50Hz | |
| 12 | Warranty | Min. 1 year full; Min. 5 years on Compressor | |

Prepared By:

Name: Er. Abhishek Pradhan
Designation: Sr. BMET
NEC Registration No.: 5194 "Elex & Comm"
Office: Civil Service Hospital, Kathmandu